

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Bero/Ren/168

Dated: - 31/07/2025

It is certified that an inspection team headed by En. Dewanand Singh

(Name of Officers with designation) from Assistant Engineer PHED

inspected the Aditya Prakash Jalan Saraswati Vidya Mandir Kudlum
Balaloug Nagri

(Name & Address of the school) on (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 138 dated 24/07/2025

of Vidya Campus (PHED Lab) certified that the

A.P.J.S.V.M. Kudlum Balaloug Nagri (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year from date of issue.

Signature with Seal: 24/07/2025

Name

Designation

Name & Address of the Office / Department


To


The Principal in charge
A.P.J.S.V.M. Kudlum Balaloug Nagri
(Name & Address of the Institution)

D.W.S. Div. Ranchi West

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

64 | Page


प्रधानाचार्य
आदित्य प्रकाश जालान सरस्वती विद्या मंदिर
श्रीकृष्ण चन्द्र गाँधी शैक्षिक नगर
कुदलुम बालालौंग, नगड़ी, राँची-834004


सचिव
आदित्य प्रकाश जालान सरस्वती विद्या मंदिर
श्रीकृष्ण चन्द्र गाँधी शैक्षिक नगर
कुदलुम, बालालौंग, नगड़ी, राँची-834004



District Level Water Testing Laboratory, Ranchi
VISWA Campus, Near Jodapool, Kanke ,
Ranchi- 834006, Jharkhand, India
Email:dlwtl.ranchi@gmail.com



TC-13614

Test Report


Report No:	Ref no.- 08	Issue Date : 24/07/2025
Issued To: (Name & Address of Customer)	The Principal, Aditya Prakash Jalan Saraswati Vidya Mandir, Balalong , Kudlum, Nagri, Ranchi. Sample no.01- Tap Water	Order Ref. No.: 39/2025-26 ULR No.: TC1361425000000124F
Date of Start Analysis :	22/07/2025	Sampling: Not done by laboratory Sample Received Date: 22/07/2025
Date of Completion Analysis :	24/07/2025	Environmental Condition of laboratory Temperature: 25.9°C Humidity: 52%

Sl. No.	Parameter	Unit	Result	Method Reference	Specification as per BIS – 10500:2012 (Second Revision) (Reaffirmed 2023)	
					Acceptable Limit	Permissible Limit (In Absence of Alternate source)
1	pH at 25 °C	-	7.95	IS 3025 (Part 11):2022,	6.5 – 8.5	No relaxation
2	Turbidity	NTU	-	IS 3025 (part 10):2023	1	5
3	Total Dissolved Solids at 180 °C	mg/L	120	IS 3025 (Part 16):2023, (Total Dissolved Solids Dried at 180 °C)	500	2000
4	Hardness as CaCO ₃	mg/L	96	IS 3025 (Part 21):2019, (EDTA Titration method)	200	600
5	Alkalinity as CaCO ₃	mg/L	92	IS 3025 (Part 23):2023, (Titration method)	200	600
6	Calcium as Ca ⁺	mg/L	20.80	IS 3025 (Part 40):2023, (EDTA Titration method)	75	200
7	Magnesium as Mg ²⁺	mg/L	10.69	IS 3025 (Part 46):2023	30	100
8	Chloride as Cl ⁻	mg/L	7.99	IS 3025 (Part 32):2019, (Argentometric method)	250	1000
9	Colour	Hazen Unit	5	IS 3025 (Part 4):2021, (Visual Comparison method)	5	15
10	Odour	-	Agreeable	IS 3025 (Part 5): 2018	Agreeable	Agreeable
11	Taste	-	Agreeable	IS 3025 (Part 7): 2017 (Taste Threshold)	Agreeable	Agreeable

Notes :-

- The results listed refer only to the tested sample and applicable parameters.
- This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- This report cannot be reproduced, except when in full, without the written permission of the Lab In-charge
- All disputes are subjected to the Ranchi Jurisdiction.

Reviewed by:-


प्रधानाचार्य

आदित्य प्रकाश जालान सरस्वती विद्या मंदिर
श्रीकृष्ण चन्द्र गाँधी शैक्षिक नगर
कुदलुम, बालालौंग, नगड़ी, राँची-834004

-End of the Report-
Page 1 of 2


(Krishna Kumar)
Chemist
Technical Manager
DLWTL, Ranchi


सचिव

आदित्य प्रकाश जालान सरस्वती विद्या मंदिर
श्रीकृष्ण चन्द्र गाँधी शैक्षिक नगर
कुदलुम, बालालौंग, नगड़ी, राँची-834004



District Level Water Testing Laboratory, Ranchi
VISWA Campus, Near Jodapool, Kanke ,
Ranchi- 834006, Jharkhand, India
Email: dlwtl.ranchi@gmail.com

Test Report

Report No:	Ref no.- 08	Issue Date : 24/07/2025
Issued To: (Name & Address of Customer)	The Principal, Aditya Prakash Jalan Saraswati Vidya Mandir, Balalong , Kudlum, Nagri, Ranchi. Sample no.01- Tap Water	
Date of Start Analysis :	22/07/2025	Sampling: Not done by laboratory Sample Received Date: 22/07/2025
Date of Completion Analysis :	24/07/2025	Environmental Condition of laboratory Temperature: 25.9°C Humidity: 52%

Sl. No.	Parameter	Unit	Result	Method Reference	Specification as per BIS – 10500:2012 (Second Revision) Amendment – June 2015	
					Acceptable Limit	Permissible Limit (In Absence of Alternate source)
01.	Fluoride	mg/L	1.0	FTK	1.0	1.5
02.	Iron	mg/L	0.0	FTK	1.0	No relaxation
03.	Total Coliform	-	Absent	H ₂ S Vial	Absent	


Notes: -


- The results listed refer only to the tested sample and applicable parameters.
- This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- This report cannot be reproduced, except when in full, without the written permission of the Lab In-charge
- All disputes are subjected to the Ranchi Jurisdiction.

Reviewed by:-


प्रधानाचार्य
आदित्य प्रकाश जालान सरस्वती विद्या मंदिर
श्रीकृष्ण चन्द्र गाँधी शैक्षिक नगर
कुदलुम, बालालौग, नगड़ी, राँची-834004

-End of the Report-
Page 2 of 2


(Krishna Kumar)
Chemist
Technical Manager
DLWTL, Ranchi


सचिव
आदित्य प्रकाश जालान सरस्वती विद्या मंदिर
श्रीकृष्ण चन्द्र गाँधी शैक्षिक नगर
कुदलुम, बालालौग, नगड़ी, राँची-834004